

表三三五～一 液密型金屬可撓導線管管徑之選定

| 導線線徑 | | 絕緣導線數 | | | | | | | | |
|------------|--------------------------|--------------|-----|-----|-----|-----|-----|-----|-----|-----|
| 單線 (mm) | 絞線 (mm ²) | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 |
| | | 導線管最小管徑 (mm) | | | | | | | | |
| 1.6 | | 16 | 16 | 16 | 16 | 20 | 20 | 20 | 25 | 25 |
| 2.0 | 3.5 | 16 | 16 | 16 | 20 | 20 | 20 | 25 | 25 | 25 |
| 2.6 | 5.5 | 16 | 16 | 20 | 20 | 25 | 25 | 25 | 32 | 32 |
| | 8 | 16 | 20 | 20 | 25 | 25 | 32 | 32 | 32 | 32 |
| | 14 | 16 | 20 | 25 | 25 | 32 | 32 | 32 | 40 | 40 |
| | 22 | 16 | 25 | 25 | 32 | 40 | 40 | 50 | 50 | 50 |
| | 30 | 16 | 32 | 32 | 32 | 40 | 50 | 50 | 50 | 63 |
| | 38 | 20 | 32 | 32 | 40 | 50 | 50 | 50 | 63 | 63 |
| | 50 | 20 | 32 | 40 | 50 | 50 | 63 | 63 | 63 | 63 |
| | 60 | 20 | 40 | 40 | 50 | 63 | 63 | 63 | 63 | 75 |
| | 80 | 25 | 40 | 50 | 50 | 63 | 63 | 75 | 75 | 75 |
| | 100 | 25 | 50 | 50 | 63 | 63 | 75 | 75 | 90 | 90 |
| | 125 | 32 | 50 | 63 | 63 | 75 | 75 | 90 | 110 | 110 |
| | 150 | 32 | 63 | 63 | 75 | 75 | 90 | 110 | 110 | |
| | 200 | 32 | 63 | 63 | 75 | 90 | 110 | | | |
| | 250 | 40 | 75 | 75 | 90 | 110 | | | | |
| | 325 | 50 | 75 | 90 | 110 | | | | | |
| | 400 | 50 | 90 | 90 | | | | | | |
| | 500 | 50 | 110 | 110 | | | | | | |

註：1. 導線一條適用於設備接地導線及直流電路。
2. 最小管徑依 CNS 規定以標稱管徑為準。